

Error Messages

- BACnet; BACnet stack initialization failed. Unable to bind <IP-address>:<port>.
- BMS_DATA_ENGINE;[xes_InvalidItemID] VLink in line: <n>
- Error installing Microsoft .NET Framework, Return Code 0x800f0906
- Export to Excel unsuccessful
- NETIP_TUNNELING_SOCKET; No valid Server IP Address can be detect.Set 'NetworkCardIPAddress' Parameter in Router Configuration file.
- NETIP_TUNNELING_SOCKET; Received Telegram: <KNX-group-address>@<IP-address> from <KNX-phys-address> has different data size as defined (defined:<x>, received:<y>).
- OPC Client callback function failed
- The NETx BMS could not be started! Check the server Log files or Windows Event List for more information.
- VNET_SERVER: Listing Socket E03. Server could not be initialized (E5177)
- WEB_SERVER; Can't start server on IP Address(es) <IP-Address> and Port: <port>
- XDB_ENGINE; Connect to SysDatabase failed.